Job #184492291

A Service

Date

2026-06-12

Technician's Name

Cody Hutson

Customer's Name

Andy Francis

Customer's Service Address

9 Monica Drive, Little Rock, AR 72204 USA

Is Customer without air or heat now?

System is Operational

Outdoor Unit Model and Serial

If there is no equipment information logged in the customer's record, PLEASE, enter info (pictures of the data tags are appreciated)



Picture of Gauges / Gas Pressure



Indoor Unit Model and Serial

If there is no equipment information logged in the customer's record, PLEASE, enter info (pictures of the data tags are appreciated)



Coil/ Heat Strips Model and Serial

If there is no equipment information logged in the customer's record, PLEASE, enter info (pictures of the data tags are appreciated)



Thermostat

If there is no equipment information logged in the customer's record, PLEASE, enter info (pictures of the data tags are appreciated)



Type of System

Air Conditioner

System Location

Attic Horizontal

Do Parts need to be ordered? If yes, please describe part

No

Description of Work Performed

Upon arrival, customers states they recently bought the home and wanted the AC inspected. After further investigation is determined that the system was low on refrigerant. Customer approved leak search. Found leak at high-pressure service valve. Was able to close off leak by turning the valve another half turn. Pressure test held for over 10 minutes. Vacuum down system below 500 µm. Refilled system with 5 pounds of 410 a refrigerant. Blower capacitor is at a six out of 10. Customer approved replacement fee. System AC is fully functional no other issues detected at this time.

Additional Notes

-

Repair Photos/ Before and After Repair

Please provide before and after pictures if repair was completed during service call







Fieldpiece
SC250
4.20
AUTO OFF


Fieldpiece
SC260
44.1
AUTO OFF


Fieldpiece
SC260
1.32
AUTO OFF


Fieldpiece
SC260
1.168
AUTO OFF






C65R
10μF
370V









Recommended Add Ons

Recommended Add Ons

Recommended Add Ons

- [x] Preventative Maintenance